

### SSL-VIBRATION User's Manual

**IMPORTANT:** Read all of the instructions before attempting to install the SSL-VIBRATION sensor.

#### DESCRIPTION

The SSL-VIBRATION sensor is a device, which connects to the SSL-EMD. When a vibration is detected an alarm will be initiated. Through the SNMP-SSL card, the user can monitor it and receive notifications of the alarms.

#### APPLICATION

SSL-VIBRATION sensor is designed for protecting against forced entry by hammer, saw, crowbar, etc. through walls, ceilings, windows, safes, cabinets, etc. It is used in closed-circuit alarm systems and will initiate an alarm when a vibration of considerable force strikes the protected surface.

#### INSTALLATION

1. Loosen the screws on SSL-EMD.




2. Connect the wires of SSL-VIBRATION sensor to the SSL-EMD Alarm-1 and/or Alarm-2, and then tighten the screws.



3. Connect the straight-through CAT5 network cable from the SNMP-SSL card's RJ45 connector labeled "COM" to the connector labeled "010101" on the SSL-EMD.




4. Verify that the SNMP-SSL card has a network connection and is powered on.
5. Check the LED (Power/Status) of SSL-EMD, it will flash every 5-seconds.
6. Open a Web browser and connect to the SNMP-SSL card.
7. Change the setting of "SSL-EMD Status" from "Disable" to "Auto" on the EMD Configuration page.
8. Set the status of Alarm-1 and/or Alarm-2 to "Normal Close".



9. Place the SSL-VIBRATION sensor in the desired location.
10. The installation of the SSL-VIBRATION sensor is complete. See the SNMP-SSL User's manual.

#### ADJUSTING THE SENSITIVITY

Loosing or tightening the adjustment screw of the vibration sensor, will adjust the sensitivity. To increase the sensitivity, tighten the screw.



#### LIMITED PRODUCT WARRANTY

Para Systems Inc. (Para Systems) warrants this equipment, when properly applied and operated within specified conditions, against faulty materials or workmanship for a period of three years from the date of original purchase by the end user. For equipment sites within the United States and Canada, this warranty covers repair or replacement of defective equipment at the discretion of Para Systems. Repair will be from the nearest authorized service center. Replacement parts and warranty labor will be borne by Para Systems. For equipment located outside of the United States and Canada, Para Systems only covers faulty parts. Para Systems products repaired or replaced pursuant to this warranty shall be warranted for the remaining portion of the warranty that applies to the original product. This warranty applies only to the original purchaser who must have properly registered the product within 10 days of purchase.

The warranty shall be void if (a) the equipment is damaged by the customer, is improperly used, is subjected to an adverse operating environment, or is operated outside the limits of its electrical specifications; (b) the equipment is repaired or modified by anyone other than Para Systems or Para Systems-approved personnel; or (c) has been used in a manner contrary to the product's operating manual or other written instructions.

Any technical advice furnished before or after delivery in regard to use or application of Para Systems's equipment is furnished without charge and on the basis that it represents Para Systems's best judgment under the circumstances, but it is used at the recipient's sole risk.

**EXCEPT AS PROVIDED HEREIN, PARA SYSTEMS MAKES NO WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.** Some states do not permit limitation of implied warranties; therefore, the aforesaid limitation(s) may not apply to the purchaser.

**EXCEPT AS PROVIDED ABOVE, IN NO EVENT WILL PARA SYSTEMS BE LIABLE FOR DIRECT, INDIRECT, SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES ARISING OUT OF THE USE OF THIS PRODUCT, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE.** Specifically, Para Systems is not liable for any costs, such as lost profits or revenue, loss of equipment, loss of use of equipment, loss of software, loss of data, cost of substitutes, claims by third parties, or otherwise. The sole and exclusive remedy for breach of any warranty, expressed or implied, concerning Para Systems's products and the only obligation of Para Systems hereunder, shall be the repair or replacement of defective equipment, components, or parts; or, at Para Systems's option, refund of the purchase price or substitution with an equivalent replacement product. This warranty gives you specific legal rights and you may also have other rights, which vary from state to state.

#### OBTAINING TECHNICAL ASSISTANCE

Para Systems (Minuteman UPS) Technical Support:  
 Phone: 1-972-446-7363  
 Fax: 1-972-446-9011  
 Web: [www.minutemanups.com/support/con\\_tech2.php](http://www.minutemanups.com/support/con_tech2.php)